

TAMIL NADU FIRE AND RESCUE SERVICE DEPARTMENT
FIRE AND RESCUE STATION – SURAMANGALAM.

Roc: No. 14/2024

Date: 25/04/2024

NO OBJECTION FIRE SAFETY CERTIFICATE

Certified that the **Sri Chaitanya Techno School at No.3/6, Perumal Malai Road, NKN Nagar, Narasothipatti, Kuranguchavadi, Salem – 636004** comprised of Ground floor and two upper floors (first and second) occupied by **Sri Chaitanya Techno School** have complied with the fire prevention and fire safety requirements in accordance with rule of Sate Fire Service Rules, and verified by the officers concerned of Fire Service on **24.04.2024** in the presence of Principal, **Sri Chaitanya Techno School** and that the building is fit for occupancy up to classes **Pre kg to XII** with effect from **24.04.2024** for a period of one year in accordance with rule and subject to compliance of specific conditions as appended:-

1. Govt. Go.No.122 School Education (2) Dept.Dt:14.09.2004
2. Govt. Go.No.123 School Education (2) Dept.Dt:14.09.2004
3. Govt. Go.No.177 School Education (2) Dept.Dt:07.09.2004
4. The Application from Principal **SRI CHAITANYA TECHNO SCHOOL,**
No: 3/6, 76/6, Perumal Malai Road, Narasothipatty, Kuranguchavadi,
Salem – 636 004. Application Date: 22/04/2024.

Issued on **25.04.2024** at Salem by

* **This Certificate is Valid For 1 Year Only.**

Signature With Seal:

Name:

SIRAJ AL VANISH.F

Designation:


STATION (F&R) OFFICER

Name & Address of Department / Office:

SURAMANGALAM STATION
SALEM

To:

The Principal
Sri Chaitanya Techno School,
No:3/6, Perumal Malai Road,
NKN Nagar, Narasothipatti,
Kuranguchavadi, Salem – 636004.



நிலைய அலுவலர்
தலைமைப்பயிற்சியுள்ளிகள் நிலையம்
குரமங்கலம், சேலம்-05

Copy To:

1. The Deputy Director TNFRS Salem Region, Nagar, Narasothipatti, Kuranguchavadi, Salem - 636 004
2. The District Officer, Salem District – 636 016.

Principal
Sri Chaitanya Techno School
No:3/6, Perumal Malai Road,
NKN Nagar, Narasothipatti,
Kuranguchavadi, Salem - 636 004

MANAGER

-PTO.

General Conditions:

- ❖ Book, files and Cloth rooms we need to fix DCP 4/6kg.
- ❖ In Electrical Room we need to Fix CO2 4.5kg.
- ❖ First Aid kit and Emergency Contact numbers should be kept in Principal, Staff Room and Security Room.
- ❖ LPG Cylinder should be maintained properly.
- ❖ Dust and Waste Material should be cleared from Campus Regularly.
- ❖ Mock Drill and Evacuation Drill to be conducted two time per Year.
- ❖ School Building and Hostel Building should be Separate.